

NTG 2010 / 3690 /



Unit 2: 2 Roni Court
Winnellie NT 0820
Phone: 8947 1066
Fax: 8947 1069
Email: Elfenbein@bigpomd.com
13 February 2013

Our Reference: 01302929RE

Certificate of Removal

Mr. and Mrs. Wagon
Pensioners Workshop
48 Albatross Street
WINNELLIE NT 0820

SUBJECT: Removal of asbestos floor Tiles and Glue – Pensioners Workshop Winnellie NT.

Dear John and Evelyn,

This is to certify the asbestos floor tiles and glue identified in the pensioner's workshop "show room" has been removed including grinding of floors in the kitchen and office areas in accordance with National Occupational Health and Safety Commissions Code of Practice for the safe removal of asbestos.

Inspection of the work area (*i.e. specific to "show room" containing the asbestos floor tiles*) verifies that the asbestos has been removed.

All exposed areas were vacuumed and PVA solution applied to all areas where asbestos had been removed.

The floor tiles and glue containing asbestos were double bagged for disposal to the Darwin City Council Shoal Bay Hazard Waste Facility.

Please feel free to contact our office if we can be of any further assistance in the asbestos services we can provide.

Yours faithfully

Roger Elfenbein

*Managing Director
Ivory International (Australia) Pty Ltd
Trading as Elfenbein and Associates
NT WorkSafe Licence Number 38447*